



Sanitary Sewer Overflow Annual Report

Division of Surface Water

Date: 02-14-2023
Facility name: City of Maumee
Ohio NPDES permit no.: 2GQ00012*CG
Period covered by report: 2022

Contact person

Name: Joe Mikolajcyk
Title: Superintendent of Sewer
Mailing address: 400 Conant St. Maumee, OH 43537
Telephone: (419)897 - 7191
Email: JMikolajczyk@maumee.org

Certification:

I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.

Name Joe Mikolajcyk **Title:** Superintendent of Sewer
(typed):

Signature:  **Date:** 2/14/23

SSO Annual Report Table 1: SSO Identification		Ohio NPDES Permit No.: 2GQ00012*CG	
Identification No. ^A	Location Description	Receiving Water ^B	Eliminated ^C
301	Regulator - Kingsbury/W. Wayne	SS - Maumee River	
302	Regulator - Ford/Front	SS - Maumee River	
303	Regulator - Kingsbury/Front	SS - Maumee River	
305	Regulator - Conant/Bridge	SS - Maumee River	
306	Regulator - Gibbs/Front	SS - Maumee River	
308	Regulator - Key/River	SS - Maumee River	
310	Overflow - Elizabeth/AWT(S)	SS - Maumee River	02/06/2023
311	Overflow - Key/Sackett	SS - Maumee River	
312	Overflow - Key/7th	SS - Maumee River	
313	Overflow - Michigan/River	SS - Maumee River	
314	Overflow - Corey/River	SS - Maumee River	
315	Overflow - Carrisbrook/River	SS - Maumee River	
316	Pump - Birch St.	SS - Maumee River	
317	Pump - Michigan/Criag	SS - Maumee River	
318	Pump - Richland/7th	SS - Maumee River	
319	Pump - Detroit/Carew	SS - Maumee River	
320	Pump - River/Miami Mannor	SS - Maumee River	
AWT	Overflow – Elizabeth/AWT (N)	SS – Maumee River	

- A. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.
- B. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)." If an SSO does not reach a receiving water, enter (None)".
- C. If an SSO has been eliminated, enter the date of elimination (MM/DD/YY).

Use additional pages as needed.
EPA 4238 (Rev. 6/14)

SSO Annual Report Table 2: SSO Event Information			Ohio NPDES Permit No.: 2GQ00012*CG
Date ^A	Identification No. ^B	Receiving Water ^C	Volume ^D
02/17/2022	303	Maumee River	.016
	305		.003
	306		.029
	312		Unknown
	313		Unknown
	315		.580
	316		1.172
02/18/2022	306	Maumee River	Unknown
03/23/22	303	Maumee River	.001
	305		.001
	312		.311
	313		Unknown
	315		.083
04/25/2022	307	Maumee River	.007
05/03/2022	312	Maumee River	.005
05/04/2022	312	Maumee River	1.05
	313		Unknown
	315		.258
	316		.384
05/06/2022	312	Maumee River	.036
05/16/2022	312	Maumee River	.044
06/07/2022	312	Maumee River	.011
06/08/2022	312	Maumee River	.037
06/16/2022	301	Maumee River	.001
	305		.011
	308		.006
	310		.001
	312		.166
	313		Unknown
	314		.012
	315		1.306
	316		.384
	318		.193

A. Enter date as "MM/DD/YY". Enter "Various" to summarize overflows of less than 1000 gallons from an SSO location

B. Enter the unique identification assigned in Table 1.

C. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)." If an SSO does not reach a receiving water, enter "None".

D. Enter estimate of volume in MG (million gallons). Enter estimate of total volume if summarizing data.

Use additional pages as needed.

SSO Annual Report Table 2: SSO Event Information			Ohio NPDES Permit No.: 2GQ00012*CG
Date ^A	Identification No. ^B	Receiving Water ^C	Volume ^D
	319		.167
07/01/2022	305	Maumee River	.001
07/05/2023	305	Maumee River	.004
07/16/2022	305	Maumee River	.007
	312		.625
	313		Unknown
	315		.034
08/21/2022	305	Maumee River	.004
	315		.042
	AWT		.006
11/27/2022	AWT	Maumee River	.002
12/15/2022	310	Maumee River	.008

- A. Enter date as "MM/DD/YY". Enter "Various" to summarize overflows of less than 1000 gallons from an SSO location
- B. Enter the unique identification assigned in Table 1.
- C. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)." If an SSO does not reach a receiving water, enter "None".
- D. Enter estimate of volume in MG (million gallons). Enter estimate of total volume if summarizing data.

Use additional pages as needed.

SSO Annual Report Table 3: Water in Basement Occurrences		Ohio NPDES Permit No.: 2GQ00012*CG
Sewershed ^A	WIB Occurrences ^B	Causes ^C
EE	1	R
Total Occurrences		

A. A sewershed is a specific geographic area, such as a city block or a subdivision, that drains to a common outlet.
 B. Enter the total number of water in basement occurrences report for the sewershed.
 C. Enter all causes that apply: W = extreme weather; E = equipment failure; P = power failure; D = debris in line; R = roots; G = grease; B = other blockages; L = Line deterioration; V = vandalism; O = other, provide details.

Use additional pages as needed.

Enter narrative analysis of WIB patterns by location, frequency and cause.

WIB reports are sporadic and few between. No major system failures or deficiencies have been identified as contributing to WIBs.